

FIRE SAFETY CERTIFICATE

No.

Dated:

Certified that the Guru Nanak Foundation Public School (name of the building or premises) at Sular Road, Patiala (address) comprised of 0 basement(s) and 03 (upper floors) owned/ occupied by Guru Nanak Foundation (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 26th March, 2024 (date of inspection) in the presence of Guru Nanak Foundation (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XI/ XII (X/ XII) With effect from 27th March, 2024 for a period of one (01) year in accordance with rule and subject to compliance of specific conditions as appended:-

NOC No. - 2203-86674-Fire/65535

1. Fire safety arrangements shall be kept in working condition.
 2. No, alteration/addition/change in use of occupancy is allowed.
 3. Occupants/owner should have trained staff to operate fire safety system.
 4. Fire officer can check the arrangements of fire safety at any time.
- Issued on 27th Mar. 2024 (date of issue) at Online (place) by

*Strike out whichever is not applicable.

Signature with Seal: राजिंदर सिंह 23/6/2024
राजिंदर सिंह, पटियाला

Name

: RAJINDER KAUSHAL

Designation

: FIRE STATION OFFICER

Name & Address of Department/ Office: FIRE BRIGADE, SAI MARKET, PATIALA

Mob:- (97800-20301)

To

Guru Nanak Foundation Public School,
Sular Road, Patiala,
(Name & Address of the Institution)

ENDORSEMENT

The No Objection-Certificate issued by Fire Service stand cancelled an annulled due to
.....
(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Punjab Fire Services
(Patiala MC)

FIRE SAFETY CERTIFICATE
ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No 2203-36674-Fire/65535

NOC Type: Renew

Dated **27-Mar-2024**

Certified that the **GURU NANAK FOUNDATION PUBLIC SCHOOL** at **SULAR ROAD, PATIALA** comprised of **0** basements and **3** (Upper floor) owned/occupied by **GURU NANAK FOUNDATION** have compiled with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **26-Mar-2024** in the presence of **GURU NANAK FOUNDATION PUBLIC SCHOOL** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **B** subdivision **B-1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **27-Mar-2024** at **Patiala MC**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **GURU NANAK FOUNDATION PUBLIC SCHOOL** ਜੋ ਕਿ **SULAR ROAD, PATIALA** ਸਮੇਤ **0** ਬੇਸਮੈਂਟ ਅਤੇ **3** (ਉੱਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **GURU NANAK FOUNDATION** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਉ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **26-Mar-2024** ਮੌਜੂਦਗੀ ਵਿੱਚ **GURU NANAK FOUNDATION PUBLIC SCHOOL** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group **B** subdivision **B-1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ ਇੱਕ ਸਾਲ ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **27-Mar-2024** ਕਿੱਥੇ **Patiala MC**.

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ /ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.

ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।

4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.

ਫਾਇਰ ਬਿਗਰੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.

ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

* *Address Details cannot be used as ownership proof.*

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitally created certificate, no signature are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਾਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

Jasjeet
4/4/24

86674 B-1

		Swar Road, Patiala
2.	Name of the address of the owner with contact no.(s)	Guru Nanak Foundation Mbr 15-16 Institutional Area Ne Hotel and JNU New Delhi
3.	Name and Address of the occupier (s) with contact no.(s)	Do
4.	Total Area of the Premises	7029-00
5.	Total Covered Area	6875-00
6.	Height of the building from the ground level	15 Mtr
7.	Number of Basements & it's area	0
8.	Number of Sanctioned floors	G+2
9.	Number of actual floors	G+2
10.	Parking Area	In Front Side
11.	Detail of surrounding properties	Left — Gurmat College Right — Market Front — Road Back — open Area
	a) Left side	
	b) Right side	
	c) Front side	
	d) Back side	
12.	Number of main gate with size	Two No. Main Gates 30 feet wide
13.	Number of fire extinguisher Installed in the building of each floor with capacity, type with ISI marking no. & date of manufacturing	Various Types of Extinguish
14.	Detail of Hose reel on each floor indicating size and length of rubber pipe	6 Nos Hose Reel 30Mtr. each
15.	Detail of wet riser, No. of Landing valve, delivery hose, pipe and hose cabinet on each floor	6 No Landing Valve 6 No. D.H 6 No. Cabinet
16.	Number of yard hydrant, with detail	—
17.	Whether basement is being used for parking, storage or Office Has the basement sprinkler system? Give details	—
18.	No. Of manual fire alarms installed in building	3 No MCP
19.	Detail of automatic fire detection system P.A system provided in the building	—
20.	Detail of control panels	—
21.	Detail of water storage capacity underground/overhead with size of tank	Overhead Tank = 10,000
22.	Detail of fire pump with head and make	Main Pump = 5 H.P
	a) Main Pump	
	b) Jockey Pump	
	c) Diesel Pump	

23.	Position of fire service inlet (2way, 3way, 4way)	—
24.	Number of Staircase with size	Two No Staircase 1.5 Mtr. each
25.	Number of lift and ramp with details of communication system	—
26.	Detail of means of escape	Door, Gate and Staircase

Jasjeet
4/4/24